

CERTIFICATE

No. 8601064

In compliance with the requirements for documentation specified in Annex III (art. 2) of the European Parliament and of the Council on the market of electrical equipment designed for use within certain voltage limits, this certificate applies to the electrical equipment:

Leakage Circuit Breaker

Model: SL6N(R60N)

Technical specification: **Rated current:6A, 10A, 16A, 20A, 25A, 32A; Ue:230~ 50/60Hz; Ui:400V; Uimp:4KV; Icn:4.5kA; I_n:30, 100, 300mA; Im/I_m:500A; Pole:1P+N**

Technical file: **VC-AN-2018090504**

Assessment Performed: **2014/35/EU, 2014/30/EU**

Category (Annex IV): **N/A**

Applied Standards: **EN 61009-1:2012/A12:2017, EN 61000-6-1:2007, EN 61000-6-3:2007/A1:2011/AC:2012**

placed on the market under the name or trade mark of

GACIA Electrical Appliance Co.,Ltd

545# Dongdajie, Baitawang Industrial Zone, Beibaixiang Wenzhou 325603, P.R. China

and produced in the manufacturing plant(s)

GACIA Electrical Appliance Co.,Ltd

545# Dongdajie, Baitawang Industrial Zone, Beibaixiang Wenzhou 325603, P.R. China

This certificate attests that all provisions described in relevant parts of the standard

EN 61009-1:2012/A12:2017, EN 61000-6-1:2007, EN 61000-6-3:2007/A1:2011/AC:2012

have been fulfilled. The CE mark as shown below can be affixed, under the responsibility of the manufacturer, after the completion of EC declaration of conformity and compliance all the relevant directives.

This certificate was first issued on **19th September 2018** and is valid until **18th September 2023** and is based on the evaluation of the technical file of the equipment/machinery device. The voluntary certification does not imply an assessment of the production and it does not permit the use of a mark of conformity or of a safety mark of the LL-C (Certification). The holder of this certificate may use this certificate together with his EC declaration of conformity. This is not NB statement. The first certificate date of issue is 19th September 2018.

Prague, 19th September 2018


Daniel Tilcer
Deputy Head of CB



validity code: **B70F84DD-5A5**

Check the validity of this certificate using this code at www.ll-c.info